

**TITLE 87  
LEGISLATIVE RULE  
FIRE COMMISSION**

**SERIES 1  
FIRE CODE**

**§87-1-1. General.**

1.1. Scope. -- This rule establishes the State Fire Code for the safeguarding of life and property from the hazards of fire and explosion.

1.2. Authority. -- This legislative rule is issued under authority of W. Va. Code §29-3-5.

1.3. Filing Date. -- April 26, 2010.

1.4. Effective Date. -- July 1, 2010.

1.5. Exemption. -- This State Fire Code has no application to personal care homes caring for three or less patients or buildings used wholly as dwelling houses for no more than two families and has no application to farm structures. Provided; however, that farm structures (1) used for group sleeping accommodations for farm workers or (2) used for educational, health care, assembly or detention/correctional occupancy are not exempt from the requirements of this State Fire Code.

1.6. Incorporation of Other Documents. -- This State Fire Code does not include a reprinting of all the requirements imposed by statute or by the incorporation of various National Standards and Codes cited in Section 4 of this rule. For ascertaining these additional standards and requirements it is necessary to make reference to these other documents.

**§87-1-2. Reporting of Fire Incidences.**

The Fire Chief of any organized public fire brigade, department or company shall report every fire and non-fire incident to the State Fire Marshal. Every fire and non-fire incident response shall be reported within thirty (30) days after the date of the incident. Provided, that any fire or explosion involving human fatality, arson or suspected arson shall be reported immediately.

**§87-1-3. Unvented Heaters.**

All unvented fuel fired heaters are prohibited for all occupancies except one (1) and two (2) family dwellings. Provided, that a single unvented fuel fired heater is permitted for demonstration purposes in authorized mercantile applications when installed in accordance with manufacturers recommendations. The single heater shall be connected to a permanent source of fuel and shall not be used as a permanent or alternate source of heating. The unvented heater shall be shut off at the end of each business day.

**§87-1-4. National Standards and Codes.**

4.1. Incorporating of National Standards and Codes. -- The standards and requirements as set out and established by the 2009 edition of "The National Fire Codes" published by the National Fire Protection Association (but not including standards and requirements directed to the operation of local fire departments, NFPA 5000, NFPA 900 and NFPA 101A) and have the same force and effect as if set out verbatim in this rule and are hereby adopted and promulgated by the State Fire Commission as a part of the State Fire Code. The State Fire Marshal shall make use of the standards and requirements within the incorporated

publications in all matters coming under his or her jurisdiction. A copy of The National Fire Codes has been filed with the Secretary of State and a copy of the Table of Contents of that publication is included in Appendix A of this rule. Information regarding the purchase of The National Fire Codes or separate volumes of the Codes may be obtained by writing to the National Fire Protection Association, Batterymarch Park, Quincy, Massachusetts 02269.

4.2. National Standards and Codes. -- Modification of Fireworks Display Rule. The "Rule of the State Fire Marshal For The Display of Fireworks" as contained in N.F.P.A. 1123 and 1126 of the 2006 edition of The National Fire Codes has the same force and effect and controls the display of fireworks as if set out verbatim in this rule and is hereby adopted and promulgated by the State Fire Commission as a part of the State Fire Code, but with subdivisions 4.2.1 and 4.2.2 changed to read as follows:

4.2.1. Upon receipt of the application at least 15 days in advance of the date set for this display, the Chief of the Fire Department shall make, or cause to be made an investigation of the site of the proposed display for the purpose of determining whether the provisions of this rule are complied with in the case of the particular display. He or she shall confer with the Chief of the Police Department, or the County Sheriff if the site for the proposed display is to be outside the limits of a municipality, about the application and whether issuance of a permit would be consistent with public safety. If a display is properly lawful, the Chief of Police or the County Sheriff, if the site of the proposed display is outside the limits of a municipality and the Chief of Fire Department shall together endorse the application, stating that they approve the display as being in conformance with all parts of the law and with this rule. Failure to approve the application by either the Fire Chief or Police Chief or County Sheriff is sufficient cause for the State Fire Marshal to deny a permit.

4.2.2. The application, following endorsement by the Chiefs of the Fire and Police Departments or County Sheriff shall be sent to the State Fire Marshal who shall then, upon receipt of evidence of financial responsibility as required by law in such cases, issue a nontransferable permit authorizing the display.

4.3. These changes to the N.F.P.A. 1123 and 1126 and contained in Subsection 4.2 of this section are made to make certain it is understood that the County Sheriff rather than City Police Chief is the local police authority referred to in W. Va. Code §29-3-24 in those situations where the proposed site of a fireworks display is outside the limits of a municipality.

4.4. National Standards and Codes, Table of Contents.

The National Fire Codes as published by National Fire Protection Association are adopted by this rule and are set forth in Appendix A of this Rule.

**§87-1-5. Sprinkler Protection and Area Limitations.**

Approved automatic sprinkler systems in accordance with the applicable NFPA Standard for Sprinkler Systems will be installed in all new buildings used for any occupancy, exceeding the area limitations noted in Appendix B at the end of this rule. Sprinkler protection for occupancies covered by Section 6 of this rule are required to provide sprinkler protection regardless of area limitations.

**§87-1-6. Sprinkler Protection (Certain Occupancies).**

6.1. All nursing, convalescent, old age, custodial care, and long term or extended care homes or institutions, existing and new, regardless of the type of construction, shall have a complete automatic sprinkler protection in accordance with Standard 13 contained within the National Fire Codes and incorporated by reference in Subsection 4.1 of this rule.

6.2. Homes or institutions caring for more than three patients shall meet the requirements of this section.

**§87-1-7. Carpet Used as Floor Covering.**

7.1. Flammability Requirements for Carpet Used As Floor Covering.

7.1.a. In institutional, health care, educational and penal occupancies, carpet shall meet a minimum value of 0.45 watts per square centimeter in all corridors and exits. Carpet in all other areas shall meet a minimum value of 0.22 watts per square centimeter.

7.1.b. Flammability requirements for carpet used as floor covering in all other occupancies shall meet a minimum value of 0.22 watts per square centimeter in all corridors and exits.

7.1.c. Any pad used under the carpet shall meet the minimum class of the carpet installed.

7.1.d. The values shall be determined by NFPA 253, Critical Radiant Flux of Floor Covering Systems.

7.2. Smoke Generation Properties of Carpet Used as Floor Covering.

7.2.a. In all occupancies smoke generation shall not exceed a maximum value of  $D_m=450$  (flaming mode).

7.2.b. The value shall be determined by ASTM E-662, Specific Optical Density of Smoke Generation by Solid Materials.

7.2.c. All test data for determining the flammability and smoke properties of carpets shall be conducted by a nationally recognized laboratory as certified by the National Voluntary Laboratory Accreditation Program.

7.2.d. Where an approved, automatic sprinkler system is installed and all floors are non-combustible, class II carpet is permitted in any location where Class I carpet is required. Where an approved automatic sprinkler system is installed and all floors are noncombustible and Class II carpet is permitted, no rating is required.

**§87-1-8. Maintenance of Fire Hazard; Order for Correcting Condition, Removal of Material, Repair, Demolition, etc.; Order to Contain Notice to Comply and Right to Appeal.**

Whenever the State Fire Marshal, by and through persons working under his or her direction, determines based upon the State Fire Code and/or on the experience and knowledge applied in the operation of his or her office (1) that any building or structure has been constructed, altered, or repaired in a manner violating the State Fire Code as promulgated prior to the commencement of the construction, alterations, or repairs, or (2) that any building or structure is being maintained or used in such a way as to endanger life or property from the hazards of fire or explosion, or (3) that any building or other structure or property of any kind, which, for want of repairs, or by reason of its age, dilapidated, or abandoned condition or for any other reason constitutes a fire hazards and is located or constructed so as to constitute a danger to other buildings, property, persons, life, or limb, or (4) that in any building or upon any premises there is located any combustible, flammable, or explosive substance or material or other condition dangerous to the safety of persons occupying the building or premises and adjacent premises and property, the State Fire Marshal shall order the condition or thing to be corrected, or combustible, flammable or explosive, items to be removed, or the building or buildings to be repaired, closed to occupants, or removed, as required by the circumstances. The order shall be promptly complied with by the owner, agent, occupant, and lessee of the premises, place, property, or thing. Any order may be expressed in the alternative, e.g. allowing repair but on the failure to repair requiring demolition. Any order by the State Fire Marshal which concludes that a fire hazard exists,

shall state what repairs and/or demolition must be accomplished, and that compliance must be completed within thirty (30) days of issuance. In the event of noncompliance, the State Fire Marshal is authorized by statute to enter into and upon the premises affected by the order and cause the building, structure, premises, or thing to be repaired, or torn down, materials removed, and all dangerous conditions remedied (as the case may be) at the expense of the owner, and shall advise that the order can be contested by entering an appeal to the State Fire Commission as outlined in Section 13 of this Rule.

**§87-1-9. Interference with Fire Protection Equipment.**

No person shall render any portable or fixed fire extinguishing system or device or any fire warning system inoperative or inaccessible except as may be necessary during emergencies, maintenance, drills or prescribed testing.

**§87-1-10. High Rise Buildings -- Fire Safety Standards and Requirements.**

10.1. General. -- Any new building or structure more than forty (40) feet in height, measured from the lowest level of fire department vehicle access to the floor of the highest normally occupied space used for human occupancy of the structure, is subject to this section for high rise buildings. This rule shall not nullify or interfere with existing city high rise ordinances or local laws previously adopted prior to September 8, 1975 relative to high rise buildings. Industrial occupancies not occupied as business offices are exempted from the provisions of this section.

10.2. Addition of Floors to Existing Buildings. -- Whenever floors are added to an existing building, which previously was not a high rise, causing the building to become a high rise, the building shall comply with this rule.

10.3. Automatic Fire Extinguishing Systems & Standpipe Systems. -- Any building or structure as defined in Subsections 10.1 or 10.2 of this Rule and used for human occupancy shall have an approved automatic fire extinguishing system throughout the entire building and standpipe systems installed in accordance with The National Fire Codes, adopted under Section 4 of this Rule. Class I Manual Standpipe Systems may be used up to 75 feet as adopted by NFPA 14, Standard for Standpipe Systems.

10.4. Fire Alarm System. -- The fire alarm system of a high rise building shall conform to the Standards imposed by Section 4 and Section 11 of this Rule.

10.5. Fire Department Voice Communication System. -- A High rise building or structure used for human occupancy that is seventy-five (75) feet in height or greater as measured in accordance with Subsection 10.1 of this Section shall have an approved electrically supervised fire department voice communication system. The Fire Department Voice Communication System shall be located at each floor level of stair enclosures, elevator lobbies, the penthouse and in any elevator designated for fire department use. This system shall be a telephone jack system unless specifically approved otherwise by the designated fire authority having jurisdiction.

10.6. High Rise Central Control Station. -- In every high rise building as defined in Subsections 10.1 and 10.2 of this Section, a central control station for Fire Department operations shall be provided in a location approved by the State Fire Marshal or the designated local fire authority. The Central Control Station shall contain: (1) the fire department voice communication system panel when required, (2) fire detection and alarm system panels, (3) status indicators for the Heating, Ventilation and Air Conditioning (HVAC), Smoke Control System, fire pumps and emergency generator and a (4) telephone approved by designated fire authority having jurisdiction. Emergency lighting shall be provided at the Central Control Station.

10.7. Emergency Power. -- A permanently installed emergency power generation system conforming

to The National Fire Codes adopted by Section 4 of this Rule shall be provided in every high rise building 75 feet in height or greater, as measured in accordance with subsection 10.1 of this Section. All power, lighting, signal, and communication facilities, required by this rule or otherwise, shall be transferable automatically to the emergency power system. The emergency power system shall be of sufficient capacity to provide service for, but not limited to, the following:

- 10.7.a. the Fire Alarm System;
- 10.7.b. exit & Other Emergency Lighting;
- 10.7.c. fire Protection Equipment;
- 10.7.d. the Smoke Management System;
- 10.7.e. the Fire Department Elevator;
- 10.7.f. the Fire Department Voice Communication System; and
- 10.7.g. the Fire Pumps.

10.8. Smoke Management. -- In all high rise buildings as defined in Subsections 10.1 and 10.2 of this Section, a smoke management system designed in accordance with NFPA 92A, Smoke-Control Systems, and 92B, Smoke Management Systems in Malls, Atria and Large Areas, shall be provided and acceptable to the State Fire Marshal.

10.9. Floor Designation. -- All stairway doors, both on the stairway and entrance side, shall indicate the floors by number. The floor number shall be in at least 6" block letters in a contrasting color.

**§87-1-11. Fire Alarm System.**

11.1. General Requirements for All Occupancies.

11.1.a. The following requirements apply in addition to NFPA 101, Life Safety Code, Chapter 9, Section 9.6 as adopted by this Rule.

11.1.b. All fire alarm systems, including all components, shall be electrically supervised. Components include pull stations, automatic detection, audio visual devices, flow switches, tamper switches and the main panel.

11.1.c. All fire alarm systems shall be tied in ahead of the main power disconnect, unless a secondary power source is provided.

11.1.d. All sprinkler systems OS & Y, P.I.V. and other Control Valves shall be electrically supervised and tied into the trouble/supervisory side of the fire alarm control panel.

11.1.e. All sprinkler systems shall be tied in so water flow will activate the general fire alarm audio visual device.

11.1.f. Flow and/or pressure switches shall be annunciated separately on the main fire alarm control panel.

11.1.g. All Health Care, and Detention and Correctional Occupancies shall be tied into a fire department or a communication center with 24-hour supervision which is responsible for receiving

emergency calls.

11.1.h. Heating, Ventilation, Air Conditioning Systems (HVAC).

11.1.h.1. All heating, ventilation, and air conditioning systems greater than 2000 CFM and less than 15,000 CFM shall have a duct type smoke detector in the return air duct or plenum for automatic shut down, to close main fan dampers and to sound a general fire alarm when activated.

11.1.h.2. All heating, ventilation, air conditioning systems greater than 15,000 CFM shall have duct type smoke detectors installed in both supply and return air ducts to automatically shut down, close main fan dampers and to sound a general fire alarm when activated.

11.1.h.3. Health Care, Detention and Correctional occupancies and high rise buildings duct detectors shall be zoned to indicate the specific air handling unit at the main fire alarm panel.

11.1.h.4. An HVAC unit which uses 100% of outside air does not require duct detectors, and shall shut down upon fire alarm activation.

11.1.h.5. HVAC Systems used as part of the smoke management systems are exempt from the requirements of this subsection.

11.1.i. Audible alarm indicating devices shall be of such character and distributed so as to be effectively heard above the ambient noise level obtained under normal conditions of occupancy. Audible alarm indicating devices shall produce signals that are distinctive from audible signals used for other purposes in the same building.

11.1.j. Visual signal devices shall be provided in all new fire alarm systems.

11.1.k. Pre-recorded or live voice evacuation instructions to occupants are permitted. Pre-recorded instructions shall be preceded by not less than 5 seconds or more than 10 seconds of a continuous alerting signal. Upon completion or failure of pre-recorded instructions, the fire alarm evacuation signal shall sound. Pre-recorded instructions shall be repeated two or more times. Live voice instructions shall be permitted to interrupt the pre-recorded message or the fire alarm evacuation signal. Audible and visual fire alarm devices shall be used only for fire alarm system.

11.1.l. Manual pull stations shall be located no greater than 200 feet from each other and at all exits. Manual pull stations shall be of the same general operational type.

11.1.m. Thermal detectors are required in the following areas in all occupancies requiring a fire alarm system and as listed or identified in NFPA 101, The Life Safety Code. Thermal detectors are not required in areas provided with sprinkler protection or dwelling units of apartments.

	AREAS	TYPE OF DETECTORS
(a)	Attic & Cockloft Spaces	Fixed Temperature
(b)	Storage Rooms	Rate of Rise
(c)	Furnace or boiler rooms	Fixed Temperature
(d)	Janitor Closets	Rate of Rise

87CSR1

- |     |   |                   |
|-----|---|-------------------|
| (e) | Kitchens  | Fixed Temperature |
| (f) | Laboratories, Home Economics, Woodworking Shops,<br>Auto Shops, Utility Rooms, & Locker Rooms | Rate of Rise      |

11.1.n. Smoke detectors are required in the following areas in all occupancies requiring fire alarm systems:

11.1.n.1. Rooms and/or areas dedicated for the location of electrical distribution panels or transformers;

11.1.n.2. Stages or Platforms; and

11.1.n.3. On each side of required smoke partition doors.

11.1.o. Smoke detectors shall be placed a maximum of 15 feet from ends of corridors or walls and 30 feet on center and in rooms open to the corridors, where required by the occupancy. Exceeding the spacing requirements will require submission of technical data for approval by the Fire Marshal. Exception: Smoke beam detectors shall be permitted in accordance with manufacturers specifications.

11.1.p. A building or structure being used for more than one occupancy shall comply with the fire alarm system requirements of the most stringent occupancy for that building or structure.

11.1.q. Hood suppression systems shall be connected to the Fire Alarm System and separately zoned.

11.1.r. A pre-signal fire alarm system is not permitted.

11.1.s. Elevators shall comply with NFPA 72.

11.2. Requirements for Educational and Day Care Occupancies.

11.2.a. A fire alarm system is required in every educational and day care occupancy, and shall meet the requirements and standards of this rule. However, classroom buildings of less than 2500 sq. ft. gross floor area with direct exiting to the outside from each classroom are not required to have a fire alarm system.

11.2.b. Open Plan Classroom Concepts require a complete smoke detection system throughout the facility.

11.2.c. Day Care Centers located in buildings other than educational facilities shall have smoke detectors installed on the ceilings of each story in front of the doors to the stairways and at no greater than 30 feet spacing in the corridors of all floors occupied by the center. Detectors shall also be installed in lounges and sleeping rooms in the center.

11.2.d. Group Day Care Centers require hardwired smoke detectors in sleeping rooms and corridors. Audio visual warning devices are required if hearing impaired individuals are in the facility. In mixed occupancies when exiting requires the use of a common corridor, an electrically supervised fire alarm system shall be installed.

11.2.e. An annunciator panel or fire alarm control panel shall be readily accessible to local fire department personnel.

## 87CSR1

11.2.f. Rate of rise thermal detectors are required in all Rest Rooms in new buildings except in fully sprinklered buildings.

11.2.g. Smoke detectors shall be installed in all corridors, except in a single story building with direct exiting to the exterior by the means of a door from every normally student occupied room.

11.2.h. An inspection tag shall be attached to each fire protection system near the main control valve, main panel, or other such appropriate and visible location as determined by the AHJ. The inspection tag shall contain the following information:

11.2.h.1. The individual performing the work;

11.2.h.2. Date of the test;

11.2.h.3. Results of the inspection and test.

### 11.3. Requirements for Assembly Occupancy.

11.3.a. A fire alarm system is required in every place of assembly where:

11.3.a.1. Occupancy is subject to 300 or more occupants;

11.3.a.2. Occupancy is subject to 100 or more occupants above or below the level of exit discharge;

11.3.a.3. The building is two (2) or more stories in height above the level of exit discharge, or two (2) or more stories below the level of exit discharge; or

11.3.a.4. Theaters with more than one audience-viewing room.

11.3.b. Annunciator panels and/or fire alarm control panels shall be readily accessible to fire department personnel.

11.3.c. Theaters and auditoriums shall provide audio visual devices. House lights in auditoriums and theaters shall be activated by the fire alarm system.

### 11.4. Requirements for Health Care and Ambulatory Care Occupancies.

11.4.a. A fire alarm system is required in every Health Care and Ambulatory Care occupancy, and the system shall meet the requirements and standards of this rule.

11.4.b. An approved automatic smoke detection system shall be installed in all corridors.

11.4.c. Manual pull stations shall be installed every 50 feet throughout the facility in patient sleeping room areas starting at the end of all corridors. All other manual pull stations shall be placed in accordance with the general requirements of this rule.

11.4.d. Fire alarm systems shall have annunciators located at all 24 hour nurse's stations, the telephone switchboard, and at the main location of the fire department's entry.

### 11.5. Requirements for Detention and Correctional Occupancies.

11.5.a. A fire alarm system is required in every Detention and Correctional occupancy and the

system shall meet the requirements and standards as provided in this subsection.

11.5.b. The annunciator panel or fire alarm control panel shall be readily accessible to fire department personnel and shall also be provided in the Detention or Correctional facility control center.

11.5.c. Manual pull stations shall be provided as set forth in general requirements of this rule. Manual pull stations may be of the security type in detention or correctional occupancies.

11.5.d. Smoke detectors shall be installed in all corridors. If no corridor exists, they shall be installed at the highest point of the cell areas.

11.5.e. Dormitory style correctional facilities shall comply with the Residential requirements of subsection 11.6 of this section.

11.6. Requirements for Residential Occupancies.

11.6.a. A fire alarm system is required for each of the groups of residential buildings, and the system shall meet the requirements and standards of this Rule.

11.6.b. Lodging and Rooming Houses protected throughout with a sprinkler system shall be provided with interconnected hardwired smoke detectors as required by NFPA 72.

11.6.c. Residential occupancies are designated in two groups. These designated groups shall comply with the requirements of this Rule. One group of occupancies includes hotels, motels, dormitories, lodging and rooming houses. The other group includes apartments only.

11.6.d. The following requirements apply to the occupancies of hotels, motels, dormitories, lodging and rooming houses.

11.6.d.1. Smoke detectors shall be placed a maximum of 15 feet from ends of corridors or walls and located 30 feet on center throughout all inside corridors. Smoke detectors shall be placed a maximum of 15 feet from ends of walls and 30 feet on center in open bay sleeping areas.

11.6.d.2. The annunciator panel or fire alarm control panel shall be readily accessible to fire department personnel and also shall be located at the registration desk.

11.6.d.3. All sleeping rooms and living areas in suites shall have an approved self-contained smoke alarm hard wired in accordance with NFPA 72, National Fire Alarm Code.

11.6.d.4. Motels and hotels having direct exterior exiting shall have a manual pull station every 75 feet located on exterior walls with the minimum requirement of one manual pull station. However, a one story motel with 16 or less sleeping rooms having direct exiting to the exterior is not required to be provided with a fire alarm system.

11.6.e. The following requirements apply to apartments.

11.6.e.1. Apartment buildings having 12 or more units or 4 or more stories in height shall have a fire alarm system. Smoke detectors shall be placed a maximum of 15 feet from the ends of corridors and walls and 30 feet on centers.

11.6.e.2. All existing apartments shall have approved self-contained smoke alarm located at the entrances to bedrooms.

## 87CSR1

11.6.e.3. All new apartments shall have an approved self-contained smoke alarm hard wired in accordance with NFPA 72, National Fire Alarm Code.

11.6.e.4. All new apartment buildings having 12 or more units or 4 or more stories in height with direct exiting to the exterior shall have manual pull stations every 75 feet on the exterior wall with a minimum requirement of one pull station per building.

### 11.7. Requirements for Mercantile Occupancies.

11.7.a. A fire alarm system is required in every mercantile occupancy over 3,000 square feet, and the system shall meet the requirements and standards as provided in this subsection.

11.7.b. If an existing Class B mercantile occupancy has a complete and approved sprinkler protection system, a fire alarm system is not required.

### 11.8. Requirements for Business Occupancies.

11.8.a. A fire alarm system is required in every business occupancy where:

11.8.a.1. The occupancy is subject to 300 or more total occupants;

11.8.a.2. The occupancy is subject to 100 or more occupants above or below the level of exit discharge; or

11.8.a.3. The building is two (2) or more stories in height above the level of exit discharge or two (2) or more stories below the level of exit discharge.

### 11.9. Requirements for Industrial Occupancies.

11.9.a. A fire alarm system is required in all Industrial Occupancies as required in The National Fire Codes NFPA 101, Life Safety Code, referred to in Section 4 of this rule.

### 11.10. Requirements for Storage Occupancies.

11.10.a. A fire alarm system is required in all Storage Occupancies as required in The National Fire Codes NFPA 101, Life Safety Code, referred to in Section 4 of this rule.

## **§87-1-12. Exit Inspections and Public Life Safety Announcements.**

12.1. Inspection of Exits. Not more than ninety (90) minutes prior to the scheduled commencement of any noncontinuous activity, event, performance, show, meeting, function, or other occasion for which people will gather in a place of assembly, the owner or his or her designee pursuant to written authority, instructions, or procedures shall inspect every required exit, way of approach to an exit, and way of departure from an exit. If the inspection reveals that any required means of egress is obstructed, inaccessible, locked, fastened, or otherwise unsuited for immediate use, the scheduled program shall not begin, nor shall admittance to the place of assembly be permitted, until necessary corrective action has been completed.

12.2. Announcements. Immediately prior to the start of a program for which 300 or more people will gather in a place of assembly, the owner or his or her authorized agent shall orally notify all attendees concerning the location of the exits to be used in case of fire or other emergency.

12.3. Records. An accurate record of all inspections, corrections, and notifications shall be kept and retained for at least two (2) years in the offices of the respective building owners. The records shall contain:

12.3.a. a brief description of each activity, event, performance, etc., including its date, time, and location;

12.3.b. the name and signature of the person who performed each requirement of this section; and

12.3.c. the date and time when each requirement was performed.

12.4. Alternatives. In case of practical difficulty or undue hardship, or in which compliance would not significantly increase life safety, the State Fire Marshal may approve or accept alternative means of accomplishing the objectives of this section.

**§87-1-13. Orders and Decisions of the State Fire Marshal; and Appeals and Procedure for Appeals from such Orders or Decisions.**

13.1. State Fire Marshal's Order and Decisions are Final and Conclusive. -- Any order or final written decision of the State Fire Marshal based upon or made in the course of the administration or enforcement of the provisions of W. Va. Code §29-3-1 et seq. based upon or made pursuant to this rule is final, unless vacated or modified upon review pursuant to the appeal rights and procedures provided by W. Va. Code §29A and this rule.

13.2. State Fire Marshal's Order And Decisions Appealed. -- Any person aggrieved by an order or final written decision of the State Fire Marshal based upon or made in the course of the administration or enforcement of the provisions of W. Va. Code §29-3-1 et seq. or made pursuant to this rule, and desiring to contest the order or written decision may file an appeal from the order or written decision with the State Fire Commission. Preservation of the right to an appeal and the procedure for the contested case is governed by this section and by W. Va. Code §29-3-1 et seq.

13.3. W. Va. Code §29-3-12(g) and (I) Inquiry and Investigation. -- The testimony which may be obtained by the State Fire Marshal pursuant to the authority in W. Va. Code §29-3-12(g) and (I) shall be obtained without compliance with the provisions in this rule governing "Procedure in Contested Cases." Where appropriate, a subsequent order by the State Fire Marshal relating to the testimony obtained is the same as any other order by the State Fire Marshal subject to the appeal rights provided in W. Va. Code §29-3-1 et seq.

13.4. Appeal Petition. -- The appeal petition shall be typewritten, styled "Appeal Petition", and the appellant shall submit an original and one (1) copy. It shall be complete in itself so as to fully state the matters contested. No telegram, telephone call, or similar communication will be regarded as an appeal petition. The petition shall contain and include the following:

13.4.a. a copy of the order or decision of the State Fire Marshal being contested;

13.4.b. a clear and concise assignment of each error which the petitioner alleges to have been committed by the State Fire Marshal in issuing the order or decision with each assignment of error being shown in separately numbered paragraphs;

13.4.c. a clear and concise statement of the facts upon which the petitioner relies as sustaining his or her assignment of errors;

13.4.d. the address to which the petitioner desires to have all notices, documents, and the final order of the State Fire Commission mailed;

13.4.e. the telephone number or numbers where the petitioner can be contacted;

13.4.f. the names and addresses of all persons having any ownership interest in the property which is the subject of the State Fire Marshal's order being contested;

13.4.g. a prayer setting forth the relief sought; and

13.4.h. the signature of the petitioner or its duly authorized officer.

13.5. Time Requirement and Manner of Filing Appeal Petition. -- The petitioner shall submit an appeal petition by personal delivery or mailed to the State Fire Commission within thirty (30) days following service upon the petitioner, or within thirty (30) days following actual receipt if service is not required or for some reason is not made of the order or decision being contested. Any appeal petition shall be sent by certified mail, return receipt requested, and is timely if postmarked within the thirty (30) day period. Any appeal petition not delivered or mailed within the thirty (30) day period is not timely filed and the order or decision of the State Fire Marshal being contested is final.

13.6. Copy of Appeal Petition to State Fire Commission. -- Upon receipt of an appeal petition, the Chairman of the State Fire Commission, through office staff, shall supply a copy of the petition to the State Fire Commission members together with an opinion by the State Fire Marshal regarding the urgency of the matter being contested. If the State Fire Marshal elects to file a response to the appeal petition, he or she shall deliver a copy of the response to the State Fire Commission and a copy to the petitioner.

13.7. Scheduling Appeal Petition for and Notice of Hearing. -- The State Fire Commission Chairman through office staff shall schedule a hearing on the appeal petition giving the petitioner and the State Fire Marshal at least ten (10) days written notice of the date, time, and place of the hearing. The notice to the petitioner shall be by personal delivery or by certified mail, return receipt requested, shall contain a short and plain statement of the matters to be considered at the hearing, and a copy of the State Fire Marshal's response, if any, to the appeal petition, and shall be mailed or personally delivered by the State Fire Marshal no later than thirty (30) days after receipt of the appeal petition. A copy of the notice to the petitioner shall be supplied to the State Fire Marshal. The hearing shall be conducted at a designated location in Charleston, West Virginia, or in the discretion of the State Fire Commission at a location within the county where the premises in question are located.

13.8. Authorized Representative. -- The petitioner may appear individually, or by counsel.

13.9. Continuances -- A motion for continuance shall not be granted unless made in writing three days before the hearing or during the hearing, in either case for good and sufficient cause. Upon consideration of a motion for continuance, the urgency of the situation shall be determined and taken into consideration. Conflicting engagements of counsel or the employment of new counsel are not good grounds for a continuance unless a motion is filed promptly after the notice of hearing has been mailed or unless extenuating circumstances are shown, which the State Fire Commission or hearing examiner considers adequate.

13.10. Absence of Petitioner or Counsel at the Scheduled Hearing -- A hearing by the Fire Commission shall not be delayed or continued due to the absence of the petitioner or his or her legal counsel at a hearing, after service of notice of the time, date, and place of the hearing. The hearing shall proceed and the case shall be submitted for decision on the part of the absent petitioner or petitioners.

13.11. Hearing Examiner -- Any member of the State Fire Commission may conduct a hearing on an appeal petition and has full authority to conduct the proceedings on an appeal petition, and when acting in that capacity shall be referred to as the hearing examiner. Alternatively, the State Fire Commission may authorize and empower an impartial attorney as a hearing examiner with the specific powers listed in W. Va. Code §29A-5-1(d).

13.12. Subpoenas and Subpoenas Duces Tecum.

13.12.a. At any hearing held under this section, the testimony of witnesses and the production of documentary evidence may be required through the use of subpoenas and subpoenas duces tecum. The State Fire Marshal may issue subpoenas and subpoenas duces tecum at the request of the petitioner, the hearing examiner or the State Fire Commission.

13.12.b. Every subpoena or subpoena duces tecum is required to prove service at least five (5) days before the return date of that subpoena, either by personal service made by any person eighteen (18) years of age, or older, or by registered or certified mail. A return acknowledgment signed by the person to whom the subpoena or subpoena duces tecum is directed is required to prove service by registered or certified mail.

13.12.c. Any party requesting a subpoena or subpoena duces tecum shall see that it is properly served. Service of a subpoena or subpoena duces tecum issued at the insistence of the State Fire Commission is the responsibility of the State Fire Commission.

13.12.d. Any public official who serves any subpoena or subpoena duces tecum is entitled to the same fee as a Sheriff who serves a witness subpoena for a circuit court of this state; and fees for the attendance and travel of witnesses are the same as for witnesses before the circuit courts of this state. All fees shall be paid by the State Fire Commission if the subpoena or subpoena duces tecum is issued at the instance of the Commission. All fees related to any subpoena or subpoena duces tecum issued at the instance of the petitioner or the State Fire Marshal shall be paid by the party requesting the subpoena or subpoena duces tecum.

13.12.e. A request for a subpoena or subpoena duces tecum shall be in writing and shall contain a statement acknowledging that the requesting party agrees to pay the required fee.

13.12.f. Any person receiving a subpoena or subpoena duces tecum issued under this section shall honor the subpoena or subpoena duces tecum as though it were issued by a circuit court of the state, and shall appear as a witness and/or produce the books, records, or papers in response to the subpoena or subpoena duces tecum. In case of disobedience or neglect of any subpoena or subpoena duces tecum served on any person or the refusal of any witness to testify to any matter regarding which he or she may be lawfully interrogated, the circuit court of the county in which the hearing is being held, upon application by the State Fire Commission, shall compel obedience by attachment proceedings for contempt as in the case of disobedience of the requirements of a subpoena or subpoena duces tecum issued from the circuit court or a refusal to testify in the circuit court.

13.13. Evidence.

13.13.a. All witnesses appearing at the hearing shall testify under oath or affirmation. Every adverse party has the right of cross-examination of witnesses who testify, and has the right to submit rebuttal evidence.

13.13.b. All relevant and material evidence, including papers, records, agency staff memoranda and documents in the possession of the State Fire Commission or the State Fire Marshal of which either party desires to avail himself or herself, may be offered and made a part of the record in the case.

13.13.c. Irrelevant, immaterial, or unduly repetitious evidence shall be excluded by the Fire Commission. Except as otherwise in this section, the rules of evidence as applied in civil cases in the circuit courts of this state shall be followed in considering the admissibility of evidence. However, when necessary to ascertain facts not reasonably susceptible of proof under those rules, reasonably authenticated evidence not admissible under those Rules may be admitted, except where precluded by the W. Va. Code or privilege,

if it is of a type commonly relied upon by reasonably prudent persons in the conduct of their affairs.

13.14. Record of Proceedings. -- All of the testimony, evidence and rulings on admissibility of evidence at any hearing shall be recorded by a certified court reporter. An official record of the hearing shall be prepared by the State Fire Commission. A transcript shall only be prepared if the Commission's final decision is appealed. The cost of the transcript shall be paid by the party requesting it.

13.15. Informal Disposition. -- At any stage of the proceedings, informal disposition may be made of any contested case by stipulation, agreed settlement, consent order, or default.

13.16. Decision by the State Fire Commission. -- Upon the conclusion of the hearing, the person designated by the State Fire Commission as hearing examiner shall prepare a decision supported by findings of fact and conclusions of law affirming, modifying, or vacating the earlier order of decision of the State Fire Marshal. The State Fire Commission may either accept, modify, or reject the hearing examiner's decision. If the Commission accepts the hearing examiner's decision it shall sign the decision. If the Commission rejects or modifies the hearing examiner's decision, it shall prepare a written decision setting forth findings of facts and conclusions of law. In either event, the order signed by the State Fire Commission shall be final unless vacated or modified upon judicial review thereof. A copy of the order shall be served on all parties to the hearing and all attorneys of record, if any, in person or by certified mail, return receipt requested.

13.17. Judicial Review. -- The petitioner or by the State Fire Marshal may appeal the Commission's decision to the circuit court of the county where the premises are located, if the appeal is filed within thirty (30) days after the date upon which party was served with a copy of the final order or decision of the State Fire Commission. The final order signed by the State Fire Commission is final if the proceedings for judicial review are not instituted within the said thirty (30) day period.

**§87-1-14. Miscellaneous Provisions.**

14.1. Forest fire season:

14.1.a. The periods of each year between March first and May thirty-first, inclusive, and October first and December thirty-first, inclusive, are designated as forest fire seasons. No person shall during any fire season, except between the hours of four o'clock p.m. and seven o'clock a.m. prevailing time, set fire to, or procure another to set fire to, any brush, leaves, grass, debris or field containing dry grass or other inflammable material capable of spreading fire, located in or within 300 feet of any woodland, brushland, or field containing dry grass or other inflammable material. Any fire set during this time shall be extinguished prior to seven o'clock a.m. prevailing time. The prohibition of fires between seven o'clock a.m. and four o'clock p.m. prevailing time does not include (1) small fires set for the purpose of food preparation, or providing light or warmth around which all grass, brush, stubble, or other debris has been removed for a distance of ten feet from the fire, and (2) burning which may be conducted at any time when the ground surrounding the burning site is covered by one inch or more of snow. Any person who sets or causes to be set any fire permitted by this section shall not leave the fire unattended for any period of time.

14.1.b. Any person or his or her agent or employee who sets or causes to be set any fire at any time in the use and occupation of any kind on which the burning was being done is in violation of this section if fire escapes beyond the safety strip. Any person who, by himself or herself, or by his or her employees, agents or guides or as an employee, agent or guide of any other person, at any time builds or use any fire in any field, on any public or private road, or in any area adjacent to or on any forest land in this state, shall before leaving the fire for any period of time, totally extinguish the fire. A person shall not at any time throw or place any lighted match, cigar, cigarette, firecracker or lighted material on any forest land, private road, public highway or railroad right-of-way within this state.

14.1.c. The State Fire Marshal may issue permits authorizing fires prohibited by this section in

accordance with W. Va. Code §§20-3-5 and 6.

14.2. Executive Order by the Governor on Open Burning.

14.2.a. On those occasions when the Governor of the State issues an Executive Order or Proclamation to ban open burning due to weather conditions, the State Fire Marshal may assist in the enforcement of the provisions of the Proclamation or Executive Order.

14.3. Outdoor Storage of Used Tires.

The storage of used tires shall comply with the following:

14.3.a. All outdoor storage of used tires shall be free from all trash and debris within the site;

14.3.b. The owner and operators of outdoor storage of used tires shall maintain controlled access to the property with only one entrance/exit, and shall install security lighting for use during evening and night time hours as designated by the State Fire Marshal;

14.3.c. All outdoor storage of used tires shall have a perimeter security chain link fence of a minimum height of six feet;

14.3.d. All storage of used tires, shredded or unshredded, shall be separated into individual piles on the property. No pile may exceed 50 feet wide by 50 feet deep by 15 feet in height;

14.3.e. In the absence of an available water supply of at least 500 GPM (gallons per minute) provided by fire hydrants within 1000 feet of the facility, a minimum of 10,000 thousand gallon water supply on the site for exclusive use of fire fighting personnel shall be established;

14.3.f. Fire lanes having a minimum of forty-five foot lanes capable of supporting fire apparatus shall be established and maintained between all tire piles;

14.3.g. A minimum of a fifty foot wide zone around the site perimeter inside the fence line shall be maintained;

14.3.h. All storage piles shall have a minimum of a thirty inch high earthen dike around each tire pile as the piles are established;

14.3.i. A maximum of eighteen tire piles may be established on a single site; and

14.3.j. No site may exceed the storage of more than three hundred thousand tires without the approval of the State Fire Marshal.

14.4. Fireworks Defined; Labels Required (W. Va. Code §29-3-23).

The term "fireworks" means and includes any combustible or explosive composition, or any substance or combination of substances, or article prepared for the purpose of producing a visible or an audible effect by combustion, explosion, deflagration or detonation. Fireworks includes blank cartridges, toy pistols, toy cannons, toy canes or toy guns in which explosives are used, the type of unmanned balloons which require fire underneath to propel them, firecrackers, torpedoes, skyrockets, roman candles, daygo bombs, or other fireworks of like construction and any fireworks containing any explosive or flammable compound, or any tablets or other device containing any explosive substance. The term "fireworks" shall not include sparklers and novelty items as specified in W. Va. Code §29-3-23, model rockets and model rocket engines, designed, sold and used for the purpose of propelling recoverable acro models and shall not include toy pistols, toy

canes, toy guns or other devices in which paper or plastic caps manufactured in accordance with the United States Department of Transportation regulations for packing and shipping of toy paper or plastic caps are used and toy paper or plastic caps manufactured as provided therein, the sale and use of which shall be permitted at all times. Each package containing toy paper or plastic caps offered for retail sale shall be labeled to indicate the maximum explosive content per cap.

14.5. Unlawful Sale, Possession or Use of Fireworks; Permit for Public Display (W. Va. Code §29-3-24).

14.5.a. Except as provided in this subsection, no person, firm, co-partnership or corporation shall offer for sale, possess, expose for sale, sell at retail, keep with intent to sell at retail, or use or explode any fireworks. The granting of permits for supervised displays of fireworks by municipalities, fair associations, amusement parks, and other organizations or groups of individuals shall be in accordance with the National Fire Codes as adopted in Section 4 of this Rule. The State Fire Marshal shall charge a scaled fee for all applications requesting permits to establish a pyrotechnics display as provided in this section. All fees required to be paid by the provisions of this section as set forth in the rule of the Fire Commission, Fee for Services Rendered, 103CSR2 shall be paid to the State Fire Marshal and thereafter deposited by him or her into a special account for the operation of the State Fire Commission. The permits may be granted upon application to State Fire Marshal and after approval of the local police and fire authorities of the community where the display is proposed to be held and the filing of a bond by the applicant as required by law. Every display shall be handled by a competent operator licensed or certified as to competency by the State Fire Marshal and shall be of composition, and character, and located, discharged or fired in a manner that in the opinion of the chief of the fire department, after proper inspection, and of the chief of police as to not be hazardous to property or endanger any person or persons. After the privilege has been granted, sales, possessions, use and distribution of fireworks for the display are lawful for that purpose only. No permit granted under this subsection is transferable.

14.5.b. The governing body or chief executive authority of the municipality shall require a bond from the licensee in a sum not less than one thousand dollars conditioned on compliance with the provisions of this section and the rules of the State Fire Commission. No municipality is required to file a bond.

14.5.c. Before any permit is issued for a pyrotechnic display, the person, firm or corporation making application for the permit shall furnish proof of financial responsibility to satisfy claims for damages to property or personal injuries arising out of any act or omission on the part of that person, firm or corporation or any agent or employee thereof, in an amount, character and form the State Fire Marshal determined as necessary for the protection of the public.

14.6. Necessity of License for Electrical Work.

14.6.a. No electrical work may be performed, offered or engaged in for compensation or hire within the State of West Virginia by any person, unless that person possesses a valid license issued by the State Fire Marshal in accordance with West Virginia Code §29-3B-2.

14.7. Necessity of NICET Certification for Fire Protection and Fire Alarm Systems.

14.7.a. No fire protection and fire alarm system maintenance, repair or inspection work may be performed, offered or engaged in for compensation or hire within the State of West Virginia by any company unless the company maintains at least one (1) employee possessing a valid certificate of competency issued by the National Institute of Certification in Engineering Technologies (NICET). All companies shall be registered with the State Fire Commission and shall provide annual information on NICET certificate holders employed by their company for the purpose of maintenance, repair or inspection activities.

14.7.b. All fire protection extinguishment devices or systems not covered in 14.7.a. shall adhere to

## 87CSR1

the following: No fire protection equipment or system installation, maintenance, repair or inspection work may be performed, offered or engaged in for compensation or hire within the State of West Virginia by any company unless the company maintains at least one (1) employee possessing a valid certificate of competency issued by the equipment or system manufacturer. All companies shall be registered with the State Fire Commission and shall provide annual information on certificate holders employed by their company for the purpose of installation, maintenance, repair or inspection activities.

### 14.8. Residential Board and Care Occupancies.

14.8.a. Application: All facilities classified as residential board and care occupancies shall conform to the Life Safety Code, NFPA 101, requirements except as modified under this subsection. This subsection does not apply to facilities with less than four (4) residents.

14.8.b. Resident sleeping rooms shall be located on first and second floors unless the facility is provided with a sprinkler system meeting the requirements of NFPA 13, Standard for Sprinkler Systems.

14.8.c. Provide at least two (2) approved remote exits from each floor; at least one (1) exit shall be a door directly to the outside without traversing any corridor or space exposed to an unprotected vertical opening.

14.8.d. Vertical Openings shall be properly enclosed on all levels above grade with hour fire rated construction. If used as a primary means of exiting all levels shall be properly enclosed with 1 hour fire rated construction.

14.8.e. Doors shall be side-hinged swinging at least 32 inches wide when located in means of egress. Bathroom doors may be 24 inches wide.

14.8.f. Existing Stairs shall be at least Class B.

14.8.g. Hazardous Areas shall be provided with one hour fire-rated separation or provided with automatic sprinkler protection and smoke tight. Doors shall be self-closing.

14.8.h. Interior Finish of walls and ceilings shall be at least Class C throughout.

14.8.i. Fire Alarm:

14.8.i.1. An electrically supervised fire alarm system shall be provided and meet the requirements of Subsections 11.1 & 11.6 of this Rule.

14.8.i.2 Individual sleeping rooms shall be provided with a single station smoke alarm hardwired in accordance with NFPA 72, National Fire Alarm Code.

14.8.j. An approved automatic sprinkler system is required in all residential board and care facilities.

14.8.k. Corridor Walls shall be at least twenty (20) minute fire-rated and smoketight.

14.8.l. Electrical System shall meet the National Electric Code.

14.8.m. Each sleeping room shall be provided with at least one (1) outside window for rescue and ventilation and shall meet the requirement for windows in one and two family dwellings of the Life Safety Code. A door directly to the outside from each sleeping room does not require an outside window.

## 87CSR1

14.8.n. Any carpet located in the facility shall meet the requirements of Section 7 of this Rule for Residential Occupancies.

14.8.o. No door in any means of egress shall be locked against egress when the building is occupied.

14.8.p. Every bathroom door lock shall be designed to permit opening of the locked door from the outside in an emergency.

14.8.q. Every closet door latch shall be such that it can be readily opened from the inside in case of emergency.

14.8.r. No stove or combustion heater shall be located as to block escape in case of fire arising from the malfunction of the stove or heater.

14.8.s. Impractical to evacuate residents in small facilities shall be located in rooms at grade with direct exiting to the outside. The corridor room door shall be 20 minute fire rated construction or its equivalent.

### 14.9. Storage of DOT Classified Fireworks Wholesale Distributors.

14.9.a. For the purposes of this subsection, the term "facility" means any building, igloo, barn, trailer, semitrailer or other mobile property.

14.9.b. Storage of Fireworks: All new and existing storage facilities for wholesale fireworks distribution in accordance with W. Va. Code §29-3-25 shall meet the following requirements:

14.9.b.1. Each storage facility shall be of fire resistive construction;

14.9.b.2. Each storage facility containing 1000 pounds or more of fireworks shall have a complete automatic sprinkler system installed in accordance with NFPA 13, Installation of Sprinkler Systems;

14.9.b.3. A storage facility shall not be located within a residential area;

14.9.b.4. A storage facility shall meet all distance requirements set forth in NFPA 1124;

14.9.b.5. Storage or sale permits shall be issued by the State Fire Marshal's Office. Permits will be issued only upon verified compliance of this rule and payment of required fee;

14.9.b.6. An owner or operator shall immediately notify the Fire Marshal's Office within 24 hours of any lost, stolen or unaccounted for fireworks;

14.9.b.7. Smoking shall not be permitted in the storage facility or within 50 feet of the storage facility. Conspicuous signs indicating "Warning -- No Smoking" shall be posted at frequent intervals throughout the storage facility;

14.9.b.8. No fireworks shall be sold to any West Virginia resident;

14.9.b.9. A fire alarm system with complete smoke detection shall be installed throughout the storage facility in accordance with this Rule;

14.9.b.10. Each display area shall contain only inert fireworks and shall be secured to prevent unauthorized access to the display area;

## 87CSR1

14.9.b.11. All sales shall be recorded and shall include the name, address, city, state and zip code, business license number and tax department number of each purchase;

14.9.b.12. A daily inventory of fireworks shall be maintained for each facility;

14.9.b.13. All vehicles transporting fireworks from a distribution facility shall be placarded in accordance with U.S. DOT requirements. If less than 1000 pounds is being transported, a placard of Class C Explosives is required. If more than 1000 pounds is being transported, a placard of Class B Explosives is required. Each vehicle used to transport fireworks shall meet the requirements of NFPA 1124, Code for the Manufacture, Transportation and Storage of Fireworks;

14.9.b.14. Each Fire Department providing emergency services to any storage facility shall be notified in writing of the existence of the storage facility. The notice shall include information as to the type of explosives and explosive hazards that are stored at the storage facility. Pre-fire planning shall be completed by the fire department prior to operating the facility;

14.9.b.15. The land surrounding each storage facility shall be kept clear of combustibles for a distance of at least 25 feet on all sides;

14.9.b.16. Each storage facility shall be securely locked in accordance with NFPA 495, Explosive Material Code;

14.9.b.17. All electrical wiring and fixtures shall meet the requirements of the National Electrical Code, Class II, Group E, Division I locations;

14.9.b.18. All Heating, Ventilation and Air Conditioning shall meet the requirements of this Rule. No open flame heating units are permitted; and

14.9.b.19. Each storage facility shall be separated from inhabited buildings, passenger railways, public highways and other storage buildings according to the distance specified in NFPA 1124, Code for the Manufacture, Transportation and Storage of Fireworks.

### 14.10. Stopping, Standing or Parking Prohibited in Specified Areas.

14.10.a. No person shall stop, stand, or park a vehicle, except when necessary to avoid conflict with other traffic or in compliance with the law or the directions of a police officer or traffic-control device, in any of the following places:

14.10.a.1. Within fifteen feet of a fire hydrant; or

14.10.a.2. Within twenty feet of the driveway entrance to any fire station and on the side of a street opposite the entrance to any fire station within seventy-five feet of the entrance when properly sign-posted.

### 14.11. Crossing Fire Hose.

No person shall drive a streetcar or vehicle over any unprotected hose of a fire department when it is laid down on any street, private driveway, or streetcar track, to be used at any fire or alarm of fire, without the consent of the fire department official in command.

### 14.12. Emergency Vehicle Permits.

## 87CSR1

14.12.a. Authorization for all fire department vehicles and firefighters to operate Class A vehicles shall be designated by their fire chief and the State Fire Marshal's Office. Vehicles authorized by W. Va. Code §17C-15-26 shall have red flashing warning lights and an audible signaling device, such as a siren, whistle or bell capable of emitting sound audible from a distance of not less than 500 feet.

14.12.b. Upon receipt of written notification from the Fire Chief of the local fire department to the State Fire Marshal requesting that an Emergency Vehicle Permit be revoked, the State Fire Marshal shall cause the permit to be revoked.

### 14.13. Correctional or Detention Facilities.

All new correctional or detention facilities as defined in the Life Safety Code shall be protected throughout with a complete automatic sprinkler system in accordance with NFPA-13, Standard for Sprinkler Systems.

### 14.14. Explosives Amendment to NFPA 495, Explosive Materials Code.

14.14.a. As soon as practical after all loaded blast holes (shot) are linked, they shall be immediately connected to a source of ignition and fired by a person legally permitted to do so.

14.14.b. Pre-loading blast holes (shots) to be fired at a later time are prohibited. In an emergency situation, this prohibition may be waived by the State Fire Marshal.

14.14.c. Section 4.6.2 of the National Fire Protection Association (NFPA) 495, Explosive Material Code, the provisions of which are adopted by reference in subsection 4.4 of this rule, is amended to provide that persons 18 years and older may be issued a Class G Special "Helper" permit to use explosives.

### 14.15. Fire Safety Separation Requirements for Mobile Home Sites.

14.15.a. No portion of a manufactured home, excluding the tongue, shall be located closer than 3 m (10ft) side to side, 2.4 m (8 ft) end to side, or 1.8 m (6 ft) end to end horizontally from any other manufactured home or community building unless the exposed composite walls and roof of either structure are without openings and constructed of materials that will provide a 1-hour fire resistance rating or the structures are separated by a 1-hour fire-rated barrier.

14.15.b. Manufactured homes shall not be positioned vertically, stacked with one over the other, in whole or in part, unless the structure is designed and approved for such installation and permitted by the authority having jurisdiction.

### 14.16. Propane Gas Training Program Certification.

Any person who installs or maintains liquefied petroleum gas systems shall complete training standards and qualifications as established by the National Propane Association Certified Employee Training Program. Exemption: Any person who installs, fuels, maintains or services a fuel gas system on a single family dwelling owned or leased, and occupied by that person.

## ALPHABETICAL INDEX – 2009 NFC CONTENTS

51A	Acetylene Cylinder Charging Plants-2006	Vol 4
30B	Aerosol Products, Manufacture and Storage-2007	Vol 3
422	Aircraft Accident/Incident Response Assessment-2004	Vol 16
407	Aircraft Fuel Servicing-2007	Vol 9
408	Aircraft Hand Portable Fire Extinguishers-2004	Vol 9
409	Aircraft Hangars-2004	Vol 9
410	Aircraft Maintenance-2004	Vol 9
402	Aircraft Rescue and Fire Fighting Operations-2008	Vol 16
403	Aircraft Rescue and Fire Fighting Services at Airports-2009	Vol 9
414	Aircraft Rescue and Fire-Fighting Vehicles-2007	Vol 9
1003	Airport Fire Fighter Professional Qualifications-2005	Vol 11
415	Airport Terminal Buildings, Fueling Ramp Drainage, Loading Walkways-2008	Vol 9
424	Airport/Community Emergency Planning-2008	Vol 16
1901	Automotive Fire Apparatus-2009	Vol 13
85	Boiler and Combustion Systems Hazards-2007	Vol 6
1989	Breathing Air Quality for Emergency Services Respiratory Protection-2008	Vol 14
1402	Building Fire Service Training Centers-2007	Vol 17
12	Carbon Dioxide Extinguishing Systems-2008	Vol 1
720	Carbon Monoxide Warning Equipment in Dwellings-2009	Vol 10
1710	Career Fire Departments, Organization and Deployment-2004	Vol 13
211	Chimneys, Fireplaces, Vents, and Solid Fuel Burning Appliances-2006	Vol 8
260	Cigarette Ignition Resistance of Components of Upholstered Furniture-2009	Vol 8
1145	Class A Foams-2006	Vol 17
499	Classification of Combustible Dusts and of Hazardous (Classified) Locations for Electrical Installations in Chemical Process Areas-2008	Vol 16
497	Classification of Flammable Liquids, Gases, or Vapors and of Hazardous (Classified) Locations For Electrical Installations in Chemical Process Areas – 2008	Vol 16
2001	Clean Agent Fire Extinguishing Systems-2008	Vol 15
1122	Code for Model Rocketry-2008	Vol 12
484	Combustible Metals-2009	Vol 10
1221	Communications, Emergency Services-2007	Vol 12
472	Competence of Responders to Hazardous Materials/Weapons of Mass Destruction Incidence-2008	Vol 9
473	Competencies for EMS Personnel Responding to Hazardous Materials/Weapons of Mass Destruction Incidents-2008	Vol 10
55	Compressed Gases and Cryogenic Fluids-2005	Vol 4
423	Construction and Protection of Aircraft Engine Test Facilities-2004	Vol 9
241	Construction, Alteration, and Demolition Operations-2004	Vol 8
306	Control of Gas Hazards on Vessels-2009	Vol 9
16	Deluge Foam-Water Sprinkler Systems and Foam-Water Spray Systems-2007	Vol 2
51	Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes-2007	Vol 4
34	Dipping and Coating Processes Using Flammable or Combustible Liquids-2007	Vol 3
1600	Disaster/Emergency Management-2007	Vol 13
17	Dry Chemical Extinguishing Systems-2009	Vol 2
32	Drycleaning Plants-2007	Vol 3
850	Electric Generating Plants-2005	Vol 7

87CSR1

70B	Electrical Equipment Maintenance-2006	Vol 16
73	Electrical Inspection for Existing Dwellings-2006	Vol 6
70E	Electrical Safety in the Workplace-2009	Vol 5
79	Electrical Standard for Industrial Machinery-2007	Vol 6
731	Electronic Premises Security Systems-2008	Vol 10
110	Emergency and Standby Power Systems-2005	Vol 8
450	Emergency Medical Services and Systems-2009	Vol 16
1250	Emergency Service Organization Risk Management-2004	Vol 17
1561	Emergency Services Incident Management System-2008	Vol 13
1071	Emergency Vehicle Technicians-2006	Vol 12
560	Ethylene Oxide for Sterilization and Fumigation, Storage, Handling, and Use of-2007	Vol 10
412	Evaluating Aircraft Rescue and Fire-Fighting Foam Equipment-2009	Vol 9
555	Evaluating Potential for Room Flashover-2009	Vol 16
265	Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls-2007	Vol 8
551	Evaluation of Fire Risk Assessments-2007	Vol 16
285	Evaluation of Flame Propagation Characteristics of Exterior Non-load-bearing Wall Assemblies-2006	Vol 9
275	Evaluation of Thermal Barriers Used Over Foam Plastic Insulation-2009	Vol 9
91	Exhaust Systems for Air Conveying of Gases, etc.-2004	Vol 7
69	Explosion Prevention Systems-2008	Vol 4
68	Explosion Protection by Deflagration Venting-2007	Vol 4
495	Explosive Materials Code-2006	Vol 10
80A	Exterior Fire Exposures-2007	Vol 16
268	Exterior Wall Assemblies, Test for Ignitability-2007	Vol 8
801	Facilities Handling Radioactive Materials-2008	Vol 11
705	Field Flame Test for Textiles and Films-2009	Vol 17
61	Fire and Dust Explosions in Agricultural and Food Processing Facilities - 2008	Vol 4
921	Fire and Explosion Investigations, Guide for-2008	Vol 17
150	Fire and Life Safety in Animal Housing Facilities-2007	Vol 8
1002	Fire Apparatus Driver/Operator Professional Qualifications-2009	Vol 11
1912	Fire Apparatus Refurbishing-2006	Vol 14
1	Fire Code-2009	Vol 1
1581	Fire Department Infection Control Program-2005	Vol 13
1500	Fire Department Occupational Safety and Health Program-2007	Vol 13
13E	Fire Department Operations in Properties Protected by Sprinkler and Standpipe Systems-2005	Vol 16
1521	Fire Department Safety Officer-2008	Vol 13
80	Fire Doors and Other Opening Protectives-2007	Vol 6
1001	Fire Fighter Professional Qualifications-2008	Vol 11
291	Fire Flow Testing and Marking of Hydrants-2007	Vol 16
1965	Fire Hose Appliances-2003	Vol 14
1963	Fire Hose Connections-2003	Vol 14
1961	Fire Hose-2007	Vol 14
1033	Fire Investigator Professional Qualifications-2009	Vol 12
1021	Fire Officer Professional Qualifications-2009	Vol 12
120	Fire Prevention and Control in Coal Mines-2004	Vol 8
122	Fire Prevention and Control in Metal/Nonmetal Mining and Metal Mineral Processing Facilities-2004	Vol 8
804	Fire Protection for Advanced Light Water Reactor Electric Generating Plants-2006	Vol 11
45	Fire Protection for Laboratories Using Chemicals-2004	Vol 3

87CSR1

914	Fire Protection in Historic Structures-2007	Vol 11
820	Fire Protection in Wastewater Treatment and Collection Facilities-2008	Vol 11
312	Fire Protection of Vessels During Construction, Conversion, Repair, and Lay-Up-2006	Vol 9
1401	Fire Protection Training Reports and Records-2006	Vol 17
703	Fire Retardant Treated Wood and Fire Retardant Coatings for Building Materials-2009	Vol 10
170	Fire Safety and Emergency Symbols-2006	Vol 8
550	Fire Safety Concepts Tree-2007	Vol 16
501A	Fire Safety Criteria for Manufactured Home Installations, Sites, and Communities-2005	Vol 10
1041	Fire Service Instructor Professional Qualificaions-2007	Vol 12
1000	Fire Service Professional Qualifications Accreditation and Certification System-2006	Vol 11
1404	Fire Service Respiratory Protection Training-2006	Vol 13
1451	Fire Service Vehicle Operations Training Program-2007	Vol 13
251	Fire Tests of Building Construction and Materials-2006	Vol 8
252	Fire Tests of Door Assemblies-2008	Vol 8
257	Fire Tests of Window and Glass Block Assemblies-2007	Vol 8
664	Fires and Explosions in Wood Processing and Woodworking Facilities-2007	Vol 10
1124	Fireworks and Pyrotechnic Articles-2006	Vol 12
1123	Fireworks Display-2006	Vol 12
2010	Fixed Aerosol Fire-Extinguishing Systems-2006	Vol 15
287	Flammability of Materials in Cleanrooms-2007	Vol 9
30	Flammable and Combustible Liquids Code-2008	Vol 3
288	Floor Fire Door Assemblies, Fire Tests of-2007	Vol 9
1150	Foam Chemicals for Fires in Class A Fuels-2004	Vol 12
102	Grandstands, Folding and Telescopic Seating, Tents, and Membrane Structures-2006	Vol 8
12A	Halon 1301 Fire Extinguishing Systems-2009	Vol 1
329	Handling Releases of Flammable and Combustible Liquids and Gases-2005	Vol 16
99	Health Care Facilities-2005	Vol 7
1583	Health-Related Fitness for Fire Department Members-2008	Vol 13
271	Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter-2004	Vol 9
418	Heliports-2006	Vol 9
221	High Challenged Fire Walls, Fire Walls, and Fire Barrier Walls-2009	Vol 8
1127	High Power Rocketry-2008	Vol 12
851	Hydroelectric Generating Plants-2005	Vol 17
99B	Hypobaric Facilities-2005	Vol 7
704	Identification of the Hazards of Materials-2007	Vol 10
1026	Incident Management Personnel Professional Qualifications-2009	Vol12
82	Incinerators, Waste and Linen Handling Systems and Equipment-2004	Vol 6
289	Individual Fuel Packages Fire Test-2009	Vol 9
1081	Industrial Fire Brigade Member Professional Qualifications-2007	Vol 12
600	Industrial Fire Brigades-2005	Vol 10
2113	Industrial Personnel, Care of Flame-Resistant Gaments-2007	Vol 15
2112	Industrial Personnel, Flame-Resistant Garments-2007	Vol 15
1141	Infrastructure For Land Development in Suburban and Rural Areas-2008	Vol 12
1911	In-service Automotive Fire Aparatus-2007	Vol 14
1962	Inspection, Care, Use of Fire Hose, Couplings, and Nozzles-2008	Vol 14
90A	Installation of Air-Conditioning and Ventilating Systems-2009	Vol 7
780	Installation of Lightning Protection Systems-2008	Vol 10

87CSR1

31	Installation of Oil-Burning Equipment-2006	Vol 3
13	Installation of Sprinkler Systems-2007	Vol 2
20	Installation of Stationary Pumps-2007	Vol 2
90B	Installation of Warm Air Heating and Air-Conditioning Systems-2009	Vol 7
1405	Land-Based Fire Fighters Who Respond to Marine Vessel Fires-2006	Vol 17
115	Laser Fire Protection-2008	Vol 8
101®	Life Safety Code®-2009	Vol 7
1983	Life Safety Rope and Equipment for Emergency Services-2006	Vol 14
805	Light Water Reactor Electric Generating Plants-2006	Vol 11
59A	Liquefied Natural Gas (LNG)-2009	Vol 4
58	Liquefied Petroleum Gas Code-2008	Vol 4
430	Liquid and Solid Oxidizers-2004	Vol 9
1992	Liquid Splash-Protective Ensembles and Clothing for a Hazardous Materials Emergencies-2005	Vol 14
1403	Live Fire Training Evolutions-2007	Vol 13
11	Low-, Medium-, and High- Expansion Foam-2005	Vol 1
35	Manufacture of Organic Coatings-2005	Vol 3
501	Manufactured Housing-2005	Vol 10
1931	Manufacturer's Design of Fire Department Ground Ladders-2004	Vol 14
303	Marinas and Boatyards-2006	Vol 9
1005	Marine Fire-Fighting for Land-Based Firefighters	Vol 11
1925	Marine Fire-Fighting Vessels-2008	Vol 14
307	Marine Terminals, Piers, and Wharves-2006	Vol 9
270	Measurement of Smoke Obscuration Using a Conical Radiant Source-2008	Vol 8
1582	Medical Programs for Fire Departments-2007	Vol 13
301	Merchant Vessels-2008	Vol 9
261	Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes-2009	Vol 8
262	Method of Test for Flame Travel and Smoke of Wires and Cables-2008	Vol 8
701	Methods of Fire Tests for Flame Propagation of Textiles and Films-2004	Vol 10
225	Model Manufactured Home Installation Standard-2005	Vol 8
1125	Model Rocket and High Power Rocket Motors-2007	Vol 12
140	Motion Picture and TV Production Facilities and Locations-2008	Vol 8
30A	Motor Fuel Dispensing Facilities-2008	Vol 3
610	Motorsports Venues-2009	Vol 17
70	National Electrical Code®-2008	Vol 5
72	National Fire Alarm Code®-2007	Vol 6
54	National Fuel Gas Code-2009	Vol 4
1981	Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services-2007	Vol 14
1852	Open-Circuit Self-Contained Breathing Apparatus (SCBA)-2008	Vol 13
1670	Operations and Training for Technical Rescue Incidents-2004	Vol 13
432	Organic Peroxide Formulations, Storage of-2002	Vol 9
86	Ovens and Furnaces-2007	Vol 6
53	Oxygen-Enriched Atmospheres-2004	Vol 16
88A	Parking Structures-2007	Vol 7
290	Passive Protection Materials for Use on LP-Gas Containers, Fire Testing-2009	Vol 9
1982	Personal Alert Safety Systems (PASS)-2007	Vol 14
274	Pipe Insulation Test to Evaluate Fire Performance Characteristics -2009	Vol 9
302	Pleasure and Commercial Motor Craft-2004	Vol 9
10	Portable Fire Extinguishers-2007	Vol 1
505	Powered Industrial Trucks Including Type Designations, Areas of Use, Maintenance, And Operations-2006	Vol 10

87CSR1

1936	Powered Rescue Tools-2005	Vol 14
1620	Pre-Incident Planning-2003	Vol 17
730	Premises Security-2008	Vol 17
654	Prevention of Fire and Dust Explosions from Manufacturing Combustible Particulate Solids-2006	Vol 10
24	Private Fire Service Mains-2007	Vol 3
1031	Professional Qualifications for Fire Inspector and Plan Examiner-2009	Vol 12
1037	Professional Qualifications for Fire Marshal	Vol 12
909	Protection of Cultural Resource Properties-2005	Vol 11
75	Protection of Information Technology Equipment-2009	Vol 6
318	Protection of Semiconductor Fabrication Facilities-2009	Vol 9
1977	Protective Clothing and Equipment for Wildland Fire Fighting-2005	Vol 14
1999	Protective Clothing for Medical Emergency Operations-2008	Vol 15
1994	Protective Ensembles for Chemical/Biological Terrorism Incidents-2007	Vol 15
1851	Protective Ensembles for Structural Firefighting and Proximity Firefighting -2008	Vol 13
1971	Protective Ensembles for Structural Firefighting and Proximity Firefighting -2007	Vol 14
1951	Protective Ensemble for Technical Rescue Incidents-2007	Vol 14
1201	Providing Emergency Services to the Public-2004	Vol 12
1035	Public Fire and Life Safety Educator Professional Qualifications-2005	Vol 12
1061	Public Safety Telecommunicator Qualifications-2007	Vol 12
496	Purged and Pressurized Enclosures for Electrical Equipment-2008	Vol 10
232	Records, Protection of-2007	Vol 8
1194	Recreational Vehicle Parks and Compgrounds-2008	Vol 12
1192	Recreational Vehicles-2008	Vol 12
405	Recurring Proficiency of Airport Fire Fighters-2004	Vol 9
1144	Reducing Structure Ignition Hazards from Wildland Fire-2008	Vol 12
1584	Rehabilitation Process for Members During Emergency Operations and Training Exercises-2008	Vol 13
502	Road Tunnels, Bridges, and Other Limited Access Highways-2008	Vol 10
498	Safe Havens for Vehicles Transporting Explosives-2006	Vol 10
326	Safeguarding Tanks and Containers-2005	Vol 9
601	Security Services in Fire Loss Prevention-2005	Vol 10
204	Smoke and Heat Venting-2007	Vol 8
105	Smoke Door Assemblies and Other Opening Protectives-2007	Vol 8
92B	Smoke Management Systems in Malls, Atria, Large Spaces-2009	Vol 7
92A	Smoke-Control Systems-2009	Vol 7
36	Solvent Extraction Plants-2004	Vol 3
33	Spray Application Using Flammable or Combustible Materials-2007	Vol 3
1964	Spray Nozzles-2008	Vol 12
13D	Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes-2007	Vol 2
13R	Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height-2007	Vol 2
901	Standard Classifications for Incident Reporting and Fire Protection Data-2006	Vol 17
14	Standpipe and Hose Systems-2007	Vol 2
77	Static Electricity-2007	Vol 16
1975	Station/Work Uniforms for Fire and Emergency Services-2004	Vol 14
37	Stationary Combustion Engines and Gas Turbines-2006	Vol 3
853	Stationary Fuel Cell Power Systems-2007	Vol 11
40	Storage and Handling of Cellulose Nitrate Film-2007	Vol 3
490	Storage of Ammonium Nitrate-2002	Vol 10

87CSR1

434	Storage of Pesticides-2002	Vol 9
111	Stored Electrical Energy Emergency and Standby Power Systems-2005	Vol 8
520	Subterranean Spaces-2005	Vol 10
655	Sulfur Fires and Explosions-2007	Vol 10
385	Tank Vehicles for Flammable and Combustible Liquids-2007	Vol 9
1006	Technical Rescuer Professional Qualifications-2008	Vol 11
76	Telecommunications Facilities-2009	Vol 6
253	Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source-2006	Vol 8
259	Test Method for Potential Heat of Building Materials-2008	Vol 8
255	Test of Surface Burning Characteristics of Building Materials-2006	Vol 8
269	Toxic Potency Data, Test for Developing-2007	Vol 8
1452	Training Fire Department Personnel to Conduct Dwelling Fire Safety Surveys-2005	Vol 17
1410	Training for Initial Emergency Scene Operations-2005	Vol 13
130	Transit and Passenger Rail Systems-2007	Vol 8
220	Types of Building Construction-2009	Vol 8
160	Use of Flame Effects Before an Audience-2006	Vol 8
1126	Use of Pyrotechnics before a Proximate Audience-2006	Vol 12
1932	Use, Maintenance, and Service Testing of In-Service Fire Department Ground Ladders-2004	Vol 14
59	Utility LP-Gas Plant Code-2008	Vol 4
1991	Vapor-Protective Ensembles for Hazardous Materials Emergencies -2005	Vol 14
52	Vehicular Fuel Systems-2006	Vol 4
96	Ventilation Control and Fire Protection of Commercial Cooking Operations-2008	Vol 7
1720	Volunteer Fire Departments, Organization and Deployment-2004	Vol 13
286	Wall and Ceiling Interior Finish-2006	Vol 9
18A	Water Additives for Fire Control-2007	Vol 2
750	Water Mist Fire Protection Systems-2006	Vol 10
15	Water Spray Fixed Systems-2007	Vol 2
1142	Water Supplies for Suburban and Rural Fire Fighting-2007	Vol 12
22	Water Tanks for Private Fire Protection-2008	Vol 3
25	Water-Based Fire Protection Systems-2008	Vol 3
214	Water-Cooling Towers-2005	Vol 8
51B	Welding, Cutting, Other Hot Work-2009	Vol 4
17A	Wet Chemical Extinguishing Systems-2009	Vol 2
18	Wetting Agents-2006	Vol 2
1906	Wildland Fire Apparatus-2006	Vol 13
1051	Wildland Fire Fighter Professional Qualifications-2007	Vol 12
1143	Wildland Fire Management-2009	Vol 12

**APPENDIX B -- SPRINKLER PROTECTION & AREA LIMITATION**

**BUILDING HEIGHT**

Type of Construction	1 Story	2 Story	More than 2 Stories and Up to 40 ft.	More than 40 feet	More than 75 feet
Type I 443					
Fire Resistive	50,000	45,000	15,000	Sec. 10-High Rise	Sec. 10-High Rise
332					
Fire Resistive	40,000	30,000	10,000	Sec. 10-High Rise	Sec. 10-High Rise
Type II 222					
Protected Non-Com.	35,000	25,000	10,000	Sec. 10-High Rise	Sec. 10-High Rise
111					
Protected Limited Combustible	30,000	20,000	8,000	Sec. 10-High Rise	Sec. 10-High Rise
000					
Unprotected Limited Unprotected Non-Com.	12,000	8,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
Type III 211					
Protected Ordinary	10,000	6,000		NOT PERMITTED	NOT PERMITTED
200					
Non-Protected Ordinary	8,000	4,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
Type IV 2HH					
Heavy Timber	9,000	6,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
Type V 111					
Protected Wood Frame	8,000	4,000	Require Sprinklers	NOT PERMITTED	NOT PERMITTED
000					
Non-Protected Wood Frame	6,000	3,000	NOT PERMITTED	NOT PERMITTED	NOT PERMITTED

Notes to Table:

- (1) The word "area" means that area enclosed by exterior or foundation walls, fire walls, or a combination of exterior or foundation walls. A fire wall shall be constructed in accordance with NFPA 221, Standard for Fire Walls and Fire Barrier Walls, with a minimum of a 2 hour fire rating. Buildings shall only be separated by one (1) two hour fire wall and areas shall be divided as equally as possible.
- (2) The phrase "not permitted" means that buildings of these heights are not permitted for the type of construction indicated.
- (3) The phrase "Section 10-High Rise" means that the building shall also comply with Section 10 of this Rule.
- (4) Types of building construction indicated in the chart are located in NFPA 220, Standard on Types of Building Construction.
- (5) Exception: Automatic sprinklers shall not be required in open parking structures as defined in NFPA 88A of Type I or Type II construction that are less than 40 feet in height as measured per 10.01.